

NON DISCRETIONARY UNTIL SUPER SEDED
FORM U-1A MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS
 (Alternative Form for Single Chamber, Completely Shop-Fabricated Vessels Only)
 As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

11087-1

1. Manufactured and certified by Precision Stainless, Inc., 501 North Belcrest, Springfield, MO 65802
(Name and address of manufacturer)

2. Manufactured for Folger Coffee Co., 400 West F. M. 1417, Sherman, TX 75090
(Name and address of purchaser)

3. Location of installation Folger Coffee Co., 400 West F. M. 1417, Sherman, TX 75090
(Name and address)

4. Type Vertical Tank 9536 -- 44486-D, Rev. C 2740 1989
(Horiz. or vert., tank) (Mfr's serial No.) (CRN) (Drawing No.) (Nat'l. Bd. No.) (Year built)

5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE. The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1 1986
Year

to A-88 -- --
Addenda (Date) Code Case No. Special Service per UG-120(d)

6. Shell: SA240 304L .187 0 2' -11.625" 19' -6.625" OAL
Matl. (Spec. No., Grade) Nom. Thk. (in.) Corr. Allow. (in.) Diam. I.D. (ft. & in.) Length (overall) (ft. & in.)

7. Seams: Weld Single Butt -- 70% -- -- Weld Double Butt -- 2
Long. (Welded, Dbl., Sngl., Lap, Butt) R.T. (Spot or Full) Eff. (%) H.T. Temp. (°F) Time (hr) Girth (Welded, Dbl., Sngl., Lap, Butt) R.T. (Spot, Partial, or Full) No. of Courses

8. Heads: (a) Matl. SA240 304L (b) Matl. --
(Spec. No., Grade) (Spec. No., Grade)

| | Location (Top, Bottom, Ends) | Minimum Thickness | Corrosion Allowance | Crown Radius | Knuckle Radius | Elliptical Ratio | Conical Apex Angle | Hemispherical Radius | Flat Diameter | Side to Pressure (Convex or Concave) |
|-----|------------------------------|-------------------|---------------------|--------------|----------------|------------------|--------------------|----------------------|---------------|--------------------------------------|
| (a) | Bottom | .218" | 0 | 36" | 3" | -- | -- | -- | -- | Concave |
| (b) | -- | | | | | | | | | |

If removable, bolts used (describe other fastenings) --
(Matl., Spec. No., Gr., Size, No.)

9. MAWP 50 psi at max. temp. 300 °F
 Min. design metal temp. +18 °F at 50 psi. Hydro. ~~pressure~~ test pressure 82 psi.

10. Nozzles, inspection and safety valve openings:

| Purpose (Inlet, Outlet, Drain) | No. | Diam. or Size | Type | Matl. | Nom. Thk. | Reinforcement Matl. | How Attached | Location |
|--------------------------------|-----|---------------|--------|------------|-----------|---------------------|--------------|----------|
| Inspection | 2 | 18" | Manway | SA240 304L | .25" | SA240 304 | Weld | Shell |
| Sponge | 1 | 6" | Pipe | SA312 304L | SCH40 | SA240 304 | Weld | -- |
| Temp. Gauge | 1 | 1" | Pipe | SA312 304L | SCH40 | -- | Weld | -- |
| Inlet-Outlet | 1-1 | 3" | Pipe | SA240 304L | SCH40 | -- | Weld | -- |

11. Supports: Skirt No Lugs -- Logs -- Other 2 support rings Attached Upper Shell Weld
(Yes or no) (No.) (No.) (Describe) (Where and how)

12. Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report: Column stub end section, item 12 Hebelor Welding Co., 8988
(Name of part, item number, Mfr's name and identifying stamp)

Vessel is a stripper column, lower section to be bolted by top 36" flange to existing customer vessel in field. Hydro-test in horizontal position. Exempted from impact testing per UHA-51.

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1. "U" Certificate of Authorization No. 11658 expires April 6, 1992.
 Date 2-19-90 Co. name Precision Stainless, Inc. Signed Douglas W. Morgan
(Manufacturer) (Representative)

CERTIFICATE OF SHOP INSPECTION

Vessel constructed by Precision Stainless, Inc. at Springfield, MO

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of Tenn. and employed by Commercial Union Insurance Co.

have inspected the component described in this Manufacturer's Data Report on Nov. 8, 19 89, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 2-19-90 Signed Oliver D. Cooper Commissions NB8793 Tenn 2445
(Authorized Inspector) (Nat'l. Board (and endorsements), State, Prov. and No.)

NON DISCRETIONARY

FORM U-2 MANUFACTURER'S PARTIAL DATA REPORT UNTIL SUPER SEDED
A Part of a Pressure Vessel Fabricated by One Manufacturer for Another Manufacturer
As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

1. Manufactured and certified by HEBELER WELDING CO., INC. 2000 Military Rd. Tonawanda, N.Y. 14150

2. Manufactured for APV Crepaco, Inc. 395 Fillmore Ave. Tonawanda, N.Y. 14150

3. Location of Installation Unknown

4. Type Vert. H1327 4214376104 1989

5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE. The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1 1986

1987 Addenda (Detail) Code Case No. Special services per UG-120(d)

6. (a) Drawing prepared by APV Crepaco (b) Description of part inspected Column stub end section

7. Postweld heat treatment: Temp. °F Time

8. Shell: SA240-304L 3/16" 35-5/8" 3"
Material, Spec. No., Grade; Nom. Thk. (in.); Corr. Allow. (in.); Diam. I.D. (ft & in.); Length (overall) (ft & in.)

9. Seams: Dbl. Butt 70% Full Fillet 1
Long. Weld, Dbl. Singl. Lap, Buttl; R.T. (Spot or Full); ER, (X); H.T. Temp. (°F); Type; Long. Weld, Dbl. Singl. Lap, Buttl; R.T. (Spot, Partial, or Full); No. of Courses

10. Heads: (a) Matl. None (b) Matl. None
(Spec. No., Grade); (Spec. No., Grade)

Table with 10 columns: Location (Top, Bottom, Ends), Minimum Thickness, Corrosion Allowance, Crown Radius, Knuckle Radius, Elliptical Ratio, Conical Apex Angle, Hemispherical Radius, Flat Diameter, Side to Pressure (Convex or Concave). Rows (a) and (b) are empty.

If removable, bolts used (describe other fastenings)

11. Type of Jacket Proof Test

12. Jacket Closure if bar, give dimensions
If bolted, describe or sketch.

13. MAWP psi at max. temp. °F. Min. design metal temp. °F at psi.
Hydro., pneu., or comb. test press. psi.

Items 14 and 15 to be completed for tube sections

14. Tubesheets: Stationary Matl. (Spec. No., Gr.), Diam. (in.) (subject to pressure), Nom. Thk. (in.), Corr. Allow. (in.), Attach. (Weld, Bolted), Floating Matl. (Spec. No., Gr.), Diam. (in.), Nom. Thk. (in.), Corr. Allow. (in.), Attach.

15. Tubes: Matl. (Spec. No., Grade), O.D. (in.), Nom. Thk. (in. or gauge), No., Type (straight or "U")

Items 16-18 incl. to be completed for inner chambers of jacketed vessels or channels of heat exchangers

16. Shell: Matl. (Spec. No., Gr.), Nom. Thk. (in.), Corr. Allow. (in.), Diam. I.D. (ft & in.), Length (overall) (ft & in.)

17. Seams: Long. Weld, Dbl. Singl. Lap, Buttl; R.T. (Spot or Full); ER, (X); H.T. Temp. (°F); Type; Long. Weld, Dbl. Singl. Lap, Buttl; R.T. (Spot, Partial, or Full); No. of Courses

18. Heads: (a) Matl. (b) Matl.
(Spec. No., Grade); (Spec. No., Grade)

Table with 10 columns: Location (Top, Bottom, Ends), Minimum Thickness, Corrosion Allowance, Crown Radius, Knuckle Radius, Elliptical Ratio, Conical Apex Angle, Hemispherical Radius, Flat Diameter, Side to Pressure (Convex or Concave). Rows (a) and (b) are empty.

If removable, bolts used (describe other fastenings)

UNTIL SUPERSEDED

NON-DISCRETIONARY

PV-10949-1

W

U

NB NATL RD 3227

CERTIFIED BY HEBELER WELDING CO. INC.

| | | | | | |
|--------|-------|-------|---------|------|---------|
| SHELL | KAWP | 50/FV | PSIG AT | 300 | OF |
| X | X | KAWP | X | X | PSIG AT |
| X | X | X | X | X | X |
| MOUNT | 20 | OF AT | 50/FV | PSIG | |
| SERIAL | HM271 | DATE | 1989 | | |

 HEBELER WELDING CO. INC.
TOWN/WANDANA, N.Y. 14150