

T-2816-1

Report Date: 11/21/95

Alabama Heat Exchangers, Inc.
5751 La Rue Steiner Rd.
Theodore, Al. 36582

CUSTOMER
HULS AMERICA INC.
P. O. BOX 889
THEODORE, AL. 36590

RECEIVED

NOV 29 1995

FANNELL & ASSOC.

VESSEL DESCRIPTION
ESTER WASH WATER STRIPPING COLUMN

Vessel Number: T-2816-1

Drawing Number: 3356B951

ASME Code stamped: Yes

Vessel designed per the ASME Boiler & Pressure Vessel Code,
Section VIII, Division 1. 1992 Edition, 1993 addenda
with Advanced Pressure Vessel, Version 5.61d

JOB NUMBER
3356-B

NAMEPLATE INFORMATION

MAWP: 50.00 PSI and Full Vacuum at 356 F
MDMT: -20 F at 50.00 PSI

Serial Number(s): _____

National Board Number(s): _____

Year built: 1995

Radiography: None

Postweld heat treated: No

Lethal service: No

Engineering Manager _____ date: ___/___/___

Q.C. Manager _____ date: ___/___/___

Authorized Inspector _____ date: ___/___/___

TABLE OF CONTENTS - Job Number : 3356-E

Vessel Components	Page
MAIN SHELL	1
Nozzle No. A1	2
Nozzle No. P1, P2 & A2	4
END CAP	6
Nozzle No. V1 & B1	7
2" 150# BLIND FLANGE	9
MAWP Report	10
MDMT Report	11
Summary Page	12

Nozzle in the shell

ASME Section VIII, Div. 1, 1992 Edition, 1994 Addenda Page 2 of 12
 Job/Quote No : 3356-B Nozzle Number: A1
 Description : 1-1/2" SCH 40 Quantity: 1
 Configuration: Nozzle passing thru the vessel, attached by a groove weld.
 : Nozzle does not pass thru a category A joint.
 Required shell thickness per UG-37(a)

Shell material : SA-312, Type TP316L, WLD Material Stress: 13432
 Shell wall, new: 0.1340 Shell wall (-12.5%), corroded: 0.1172
 $t_r = P R_o / (SE + 0.4P)$
 $t_r = 50 * 3.3125 / (13432 * 1 + 0.4 * 50) = 0.0123$

Flange Class:150	Material Gr.: 2.3, 316L	Maximum Pressure: 167
Nozzle Material: SA-312 TP316L WLD		Condition: HIGH
Stress (hot) : 13432 PSI		Stress (cold): 14200 PSI
Nozzle pipe size : 1.5		Nozzle pipe schedule: 40
Joint efficiency E1: 1.00	Nozzle corrosion allowance: 0.0000 In.	
Nozzle ID, new : 1.6100 In.	Nozzle wall, new: 0.1450 In.	
Nozzle ID, corroded: 1.6100 In.	Nozzle wall, corroded: 0.1450 In.	
OD, limit of reinf : 3.2200 In.	Correction factor F: 1.00	
External projection: 6.0000 In.	Internal projection: 0.9375 In.	
Outer "h" limit : 0.2930 In.	Internal "h" limit: 0.2930 In.	
Upper weld, weld 41: 0.1340 In.	Internal weld, weld 43: 0.1340 In.	
Groove weld depth : 0.1340 In.		

fr1= $S_n/S_v = 13432 / 13432 = 1.000$ fr2= $S_n/S_v = 13432 / 13432 = 1.000$
 fr3= $S_n/S_v = 13432 / 13432 = 1.000$
 exempt per UHA-51(a)

Minimum Design Metal Temperature: -20 F

UG-45 Calculations

The wall thickness shall not be less than the greater of the following:

UG-45(a) - thickness for pressure loading plus corrosion.

$t = (P R_n / (SE - 0.6 P)) + CA$ nozzle efficiency(E): 100 %
 $t = (50 * 0.8050 / (13432 * 1.00 - 0.6 * 50)) + 0.0000 = 0.0030$ In.

UG-45(b) - the smaller of UG-45(b)(3) or UG-45(b)(4):

UG-45(b)(3) - the greater of UG-45(b)(1) or UG-45(b)(2):

UG-45(b)(1) - the thickness (plus CA) required for internal pressure.

$t = P R_o / (SE + 0.4P) + \text{corrosion}$
 $t = 50 * 3.3125 / (13432 * 1 + 0.4 * 50) + 0.0000 : 0.0123$ In.

UG-45(b)(2) - the thickness (plus CA) required for external pressure.

$t = P R_o / (SE + 0.4P) + \text{corrosion}$
 $t = (15.00 * 3.3125 / (13432 * 1 + 0.4 * 15.00)) + 0.0000 : 0.0037$ In.

UG-45(b)(4) - minimum thickness of standard wall pipe plus CA : 0.1269 In.

UG-45(b) = 0.0123 In.

Wall thickness for pipe = $t_n * 0.875$

Wall thickness of 0.1269 is greater than or equal to UG-45 value of 0.0123

Reinforcement calculations are not required per UG-36(c)(3)(a)

Job/Quote No: 3856-E

Nozzle Number: A1

Nozzle Description: 1-1/2" SCH 40

Page 3 of 12

Check the welds per UW-16

tmin, weld 41 = lesser of 0.75 or t or tn = 0.75 or 0.1172 or 0.1450 = 0.1172

Weld 41, leg min.=(lesser of 0.25 or (tmin * 0.7))/0.7 = 0.0820 / 0.7 = 0.1172

Weld 41, actual weld leg = 0.1340

tmin, weld 43 = lesser of 0.75 or t or tn = 0.75 or 0.1172 or 0.1450 = 0.1172

Weld 43, leg min.=(lesser of 0.25 or (tmin * 0.7))/0.7 = 0.0820 / 0.7 = 0.1172

Weld 43, actual weld leg = 0.1340

Unit Stresses per UG-45(c) and UW-15

Nozzle wall in shear	= 0.70 * 13432	=	9402 PSI
Upper fillet, weld 41, in shear	= 0.49 * 13432	=	6582 PSI
Vessel groove weld in tension	= 0.74 * 13432	=	9940 PSI
Inner fillet, weld 43, in shear	= 0.49 * 13432	=	6582 PSI

Strength of connection elements

Nozzle wall in shear	= Pi/2 * mean nozzle diameter * tn * 9402	=	3800 Lbs.
	= 1.57 * 1.7550 * 0.1450 * 9402	=	3800 Lbs.
Upper fillet in shear	= Pi/2 * nozzle O.D. * weld leg * 6582	=	2600 Lbs.
	= 1.57 * 1.9000 * 0.1340 * 6582	=	2600 Lbs.
Groove weld tension	= Pi/2 * nozzle O.D. * weld leg * 9940	=	4000 Lbs.
	= 1.57 * 1.9000 * 0.1340 * 9940	=	4000 Lbs.
Inner fillet in shear	= Pi/2 * nozzle O.D. * weld leg * 6582	=	2600 Lbs.
	= 1.57 * 1.9000 * 0.1340 * 6582	=	2600 Lbs.

Load to be carried by welds, per UG-41(b)(1) and Fig. UG-41.1 sketch (a)

$$W = [A - (d - 2t_n)(E_{lt} - F_{tr})]s = [0.0198 - (1.6100 - 2 * 0.1450) \\ (1.00 * 0.1172 - 1.00 * 0.0123)] * 13432 = -1500 \text{ Lbs.}$$

$$W1-1 = (A2 + A5 + A41 + A42) * S \\ = (0.0832 + 0.0000 + 0.0180 + 0.0000) * 13432 = 1400 \text{ Lbs.}$$

$$W2-2 = (A2 + A3 + A41 + A43 + 2t_n * t * fr1) S = (0.0832 + 0.0850 \\ + 0.0180 + 0.0180 + 2 * 0.1450 * 0.1172 * 1.000) * 13432 = 3200 \text{ Lbs.}$$

$$W3-3 = (A2 + A3 + A5 + A41 + A42 + A43 + 2t_n * t * fr1) S \\ = (0.0832 + 0.0850 + 0.0000 + 0.0180 + 0.0000 + 0.0180 \\ + 2 * 0.1450 * 0.1172 * 1.000) * 13432 = 3200 \text{ Lbs.}$$

Check strength paths

Path 1-1 =	2600 + 3800	=	6400 Lbs.
Path 2-2 =	2600 + 4000 + 2600	=	9200 Lbs.
Path 3-3 =	2600 + 2600 + 4000	=	9200 Lbs.

Nozzle in the shell

ASME Section VIII, Div. 1, 1992 Edition, 1994 Addenda Page 4 of 12
 Job/Quote No : 3356-B Nozzle Number: P1, P2 & A2
 Description : 2" SCH 40 Quantity: 3
 Configuration: Nozzle passing thru the vessel, attached by a groove weld.
 : Nozzle does not pass thru a category A joint.

Required shell thickness per UG-37(a)

Shell material : SA-312, Type TP316L, WLD Material Stress: 13432
 Shell wall, new: 0.1340 Shell wall (-12.5%), corroded: 0.1172
 $t_r = P R_o / (SE + 0.4P)$
 $t_r = 50 * 3.3125 / (13432 * 1 + 0.4 * 50) = 0.0123$

Flange Class:150 Material Gr.: 2.3, 316L Maximum Pressure: 167
 Nozzle Material: SA-312 TP316L WLD Condition: HIGH
 Stress (hot) : 13432 PSI Stress (cold): 14200 PSI
 Nozzle pipe size : 2 In Nozzle pipe schedule: 40
 Joint efficiency E1: 1.00 Nozzle corrosion allowance: 0.0000 In.
 Nozzle ID, new : 2.0670 In. Nozzle wall, new: 0.1540 In.
 Nozzle ID, corroded: 2.0670 In. Nozzle wall, corroded: 0.1540 In.
 OD, limit of reinf : 4.1340 In. Correction factor F: 1.00
 External projection: 6.0000 In. Internal projection: 0.0000 In.
 Outer "h" limit : 0.2930 In. Internal "h" limit: 0.2930 In.
 Upper weld, weld 41: 0.1340 In. Internal weld, weld 43: 0.0000 In.
 Groove weld depth : 0.1340 In.

$f r_1 = S_n / S_v = 13432 / 13432 = 1.000$ $f r_2 = S_n / S_v = 13432 / 13432 = 1.000$
 $f r_3 = S_n / S_v = 13432 / 13432 = 1.000$
 exempt per UHA-51(a)

Minimum Design Metal Temperature: -20 F

UG-45 Calculations

The wall thickness shall not be less than the greater of the following:

UG-45(a) - thickness for pressure loading plus corrosion.

$t = (P R_n / (SE - 0.6 P)) + CA$ nozzle efficiency(E): 100 %
 $t = (50 * 1.0335 / (13432 * 1.00 - 0.6 * 50)) + 0.0000 = 0.0039$ In.

UG-45(b) - the smaller of UG-45(b)(3) or UG-45(b)(4):

UG-45(b)(3) - the greater of UG-45(b)(1) or UG-45(b)(2):

UG-45(b)(1) - the thickness (plus CA) required for internal pressure.

$t = P R_o / (SE + 0.4P) + \text{corrosion}$
 $t = 50 * 3.3125 / (13432 * 1 + 0.4 * 50) + 0.0000 : 0.0123$ In.

UG-45(b)(2) - the thickness (plus CA) required for external pressure.

$t = P R_o / (SE + 0.4P) + \text{corrosion}$
 $t = (15.00 * 3.3125 / (13432 * 1 + 0.4 * 15.00)) + 0.0000 : 0.0057$ In.

UG-45(b)(4) - minimum thickness of standard wall pipe plus CA : 0.1347 In.

UG-45(b) = 0.0123 In.

Wall thickness for pipe = $t_n * 0.875$

Wall thickness of 0.1347 is greater than or equal to UG-45 value of 0.0123

Reinforcement calculations are not required per UG-36(c)(3)(a)

Check the welds per UW-16

$$t_{min}, \text{ weld } 41 = \text{lesser of } 0.75 \text{ or } t \text{ or } t_n = 0.75 \text{ or } 0.1172 \text{ or } 0.1540 = 0.1172$$

$$\text{Weld } 41, \text{ leg min.} = (\text{lesser of } 0.25 \text{ or } (t_{min} * 0.7)) / 0.7 = 0.0820 / 0.7 = 0.1172$$

$$\text{Weld } 41, \text{ actual weld leg} = 0.1340$$

Unit Stresses per UG-45(c) and UW-15

Nozzle wall in shear	= 0.70 * 13432	=	9402 PSI
Upper fillet, weld 41, in shear	= 0.49 * 13432	=	6582 PSI
Vessel groove weld in tension	= 0.74 * 13432	=	9940 PSI

Strength of connection elements

Nozzle wall in shear	= $\text{Pi}/2 * \text{mean nozzle diameter} * t_n * 9402$	=	5000 Lbs.
	= 1.57 * 2.2210 * 0.1540 * 9402	=	
Upper fillet in shear	= $\text{Pi}/2 * \text{nozzle O.D.} * \text{weld leg} * 6582$	=	3300 Lbs.
	= 1.57 * 2.3750 * 0.1340 * 6582	=	
Groove weld tension	= $\text{Pi}/2 * \text{nozzle O.D.} * \text{weld leg} * 9940$	=	4300 Lbs.
	= 1.57 * 2.3750 * 0.1172 * 9940	=	

Load to be carried by welds, per UG-41(b)(1) and Fig. UG-41.1 sketch (a)

$$W = [A - (d - 2t_n)(E1t - Ftr)]s = [0.0254 - (2.0670 - 2 * 0.1540) (1.00 * 0.1172 - 1.00 * 0.0123)] * 13432 = -2100 \text{ Lbs.}$$

$$W1-1 = (A2 + A5 + A41 + A42) * S = (0.0880 + 0.0000 + 0.0180 + 0.0000) * 13432 = 1400 \text{ Lbs.}$$

$$W2-2 = (A2 + A3 + A41 + A43 + 2t_n * t * fr1) S = (0.0880 + 0.0000 + 0.0180 + 0.0000 + 2 * 0.1540 * 0.1172 * 1.000) * 13432 = 1900 \text{ Lbs.}$$

$$W3-3 = (A2 + A3 + A5 + A41 + A42 + A43 + 2t_n * t * fr1) S = (0.0880 + 0.0000 + 0.0000 + 0.0180 + 0.0000 + 0.0000 + 2 * 0.1540 * 0.1172 * 1.000) * 13432 = 1900 \text{ Lbs.}$$

Check strength paths

Path 1-1 =	3300 +	5000	=	8300 Lbs.	
Path 2-2 =	3300 +	4300	=	7600 Lbs.	
Path 3-3 =	3300 +	0 +	4300	=	7600 Lbs.

Nozzle in an ellipsoidal head

ASME Section VIII, Div. 1, 1992 Edition, 1994 Addenda Page 7 of 12
Job/Quote No : 3356-E Nozzle Number: VI & E1
Description : 2" SCH 40 Quantity: 2
Configuration: Nozzle passing thru the vessel, attached by a groove weld.

: Nozzle does not pass thru a category A joint.

Required head thickness per UG-37(a)

Head material : SA-403, Type 316L WP-W Material Stress: 13432

Head wall, nom.: 0.1340 Head wall, corroded and thinned: 0.1172

tr = P K1 Do / (2 SE + 0.8 P)

tr = 50 * 0.90 * 6.6250 / (2 * 13432 * 1 + 0.8 * 50) = 0.0111

Flange Class: 150 Material Gr.: 2.3, 316L Maximum Pressure: 167
Nozzle Material: SA-312 TP316L WLD Condition: HIGH
Stress (hot) : 13432 PSI Stress (cold): 14200 PSI
Nozzle pipe size : 2 In Nozzle pipe schedule: 40
Joint efficiency E1: 1.00 Nozzle corrosion allowance: 0.0000 In.
Nozzle ID, new : 2.0670 In. Nozzle wall, new: 0.1540 In.
Nozzle ID, corroded: 2.0670 In. Nozzle wall, corroded: 0.1540 In.
OD, limit of reinf : 4.1340 In. Correction factor F: 1.00
External projection: 6.0000 In. Internal projection: 0.0000 In.
Outer "h" limit : 0.2930 In. Internal "h" limit: 0.2930 In.
Upper weld, weld 41: 0.1340 In. Internal weld, weld 43: 0.0000 In.
Groove weld depth : 0.1340 In.

fr1 = Sn/Sv = 13432 / 13432 = 1.000

fr2 = Sn/Sv = 13432 / 13432 = 1.000

fr3 = Sn/Sv = 13432 / 13432 = 1.000

exempt per UHA-51(a)

Minimum Design Metal Temperature: -20 F

UG-45 Calculations

The wall thickness shall not be less than the greater of the following:

UG-45(a) - thickness for pressure loading plus corrosion.

t = (P Rn / (SE - 0.6 P)) + CA nozzle efficiency(E): 100 %
t = (50 * 1.0335 / (13432 * 1.00 - 0.6 * 50)) + 0.0000 = 0.0039 In.

UG-45(b) - the smaller of UG-45(b)(3) or UG-45(b)(4):

UG-45(b)(3) - the greater of UG-45(b)(1) or UG-45(b)(2):

UG-45(b)(1) - the thickness (plus CA) required for internal pressure.

t = P K Do / (2 SE + 2P (K - 0.1)) + corrosion : 0.0123 In.
t = 50 * 1.00 * 6.6250 / (2 * 13432 * 1 + 2 * 50 (1.00 - 0.1)) + 0.0000

UG-45(b)(2) - the thickness (plus CA) required for external pressure.

t = P K Do / (2 SE + 2P (K - 0.1)) + corrosion : 0.0037 In.
t = 15 * 1.00 * 6.6250 / (2 * 13432 * 1 + 2 * 15 (1.00 - 0.1)) + 0.0000

UG-45(b)(4) - minimum thickness of standard wall pipe plus CA : 0.1347 In.

UG-45(b) = 0.0123 In.

Wall thickness for pipe = tn * 0.875

Wall thickness of 0.1347 is greater than or equal to UG-45 value of 0.0123

Reinforcement calculations are not required per UG-36(c)(8)(a)

Job/Quote No: 3356-B

Nozzle Number: V1 & B1

Nozzle Description: 2" SCH 40

Page 8 of 12

Check the welds per UW-16

$$t_{min}, \text{ weld } 41 = \text{ lesser of } 0.75 \text{ or } t \text{ or } t_n = 0.75 \text{ or } 0.1172 \text{ or } 0.1540 = 0.1172$$

$$\text{Weld } 41, \text{ leg min.} = (\text{lesser of } 0.25 \text{ or } (t_{min} * 0.7)) / 0.7 = 0.0820 / 0.7 = 0.1172$$

$$\text{Weld } 41, \text{ actual weld leg} = 0.1340$$

Unit Stresses per UG-45(c) and UW-15

Nozzle wall in shear	= 0.70 * 13432	=	9402 PSI
Upper fillet, weld 41, in shear	= 0.49 * 13432	=	6582 PSI
Vessel groove weld in tension	= 0.74 * 13432	=	9940 PSI

Strength of connection elements

Nozzle wall in shear	= $\text{Pi}/2 * \text{mean nozzle diameter} * t_n * 9402$	=	5000 Lbs.
	= 1.57 * 2.2210 * 0.1540 * 9402	=	
Upper fillet in shear	= $\text{Pi}/2 * \text{nozzle O.D.} * \text{weld leg} * 6582$	=	3300 Lbs.
	= 1.57 * 2.3750 * 0.1340 * 6582	=	
Groove weld tension	= $\text{Pi}/2 * \text{nozzle O.D.} * \text{weld leg} * 9940$	=	4300 Lbs.
	= 1.57 * 2.3750 * 0.1172 * 9940	=	

Load to be carried by welds, per UG-41(b)(1) and Fig. UG-41.1 sketch (a)

$$W = [A - (d - 2t_n)(E_{lt} - F_{tr})]s = [0.0229 - (2.0670 - 2 * 0.1540) * 13432] * 13432 = -2100 \text{ Lbs.}$$

$$W1-1 = (A2 + A5 + A41 + A42) * S = (0.0880 + 0.0000 + 0.0180 + 0.0000) * 13432 = 1400 \text{ Lbs.}$$

$$W2-2 = (A2 + A3 + A41 + A43 + 2t_n * t * fr1) S = (0.0880 + 0.0000 + 0.0180 + 0.0000 + 2 * 0.1540 * 0.1172 * 1.000) * 13432 = 1900 \text{ Lbs.}$$

$$W3-3 = (A2 + A3 + A5 + A41 + A42 + A43 + 2t_n * t * fr1) S = (0.0880 + 0.0000 + 0.0000 + 0.0180 + 0.0000 + 0.0000 + 2 * 0.1540 * 0.1172 * 1.000) * 13432 = 1900 \text{ Lbs.}$$

Check strength paths

Path 1-1 =	3300 +	5000	=	8300 Lbs.	
Path 2-2 =	3300 +	4300	=	7600 Lbs.	
Path 3-3 =	3300 +	0 +	4300	=	7600 Lbs.

Flange description: 2" 150# BLIND FLANGE

Design Pressure : 50.00 PSI

Corrosion Allowance: 0.0000 in.

Static Head: 0.00 PSI

Design Temperature: 356 F

Flange Material : SA-182 F316L

Condition: HIGH

Hot Stress (Sfc): 14632 PSI

Cold Stress (Sfa): 16300 PSI

Flange Weight : 6.0 lb

Flange MAWP (at design): 561.14 PSI

exempt per UHA-51(a)

Minimum Design Metal Temperature: -20 F

Bolting Material: SA-193 Gr EBM

Condition: 1

Hot Stress (Sb) : 14872 PSI

Cold Stress (Sa) : 18800 PSI

Gasket and Facing Details

Gasket Material : GARLOCK 3100

Gasket Type :

Gasket Factor m: 2.80

Configuration : Ring type

Seating stress y: 3150 PSI

Seating column : Column I

Facing sketch: 1a

Gasket width (N): 0.5000 in.

O.D. contact face: 3.6250 in.

Bolting Details

Number of bolts : 4

Nominal bolt diameter (a): 0.6250 in.

Bolt root area : 0.2020 in²

Bolt hole diameter: 0.7500 in.

Flange Dimensions

End diameter(ID): 0.0000 in.

Bolt circle (C) : 4.3750 in.

Outside diameter (A): 6.0000 in.

Head factor C : 0.300

Weld Efficiency (%) : 100

Gasket Seating Calculations (Table 2-5.2)

$$b_0 = N / 2 = 0.5000 / 2 = 0.2500 \text{ in.}$$

Since $b_0 \leq 1/4 \text{ in.}$, $b = b_0 = 0.2500 \text{ in.}$

$$G = (\text{O.D. contact face}) - N = 3.1250 \text{ in.}$$

Load and Bolting Calculations

$$\text{Min. } W_{m2} = (\pi) b G y = \pi * 0.2500 * 3.1250 * 3150 = 7731 \text{ lb}$$

$$H = (\pi/4)(G^2)P = (\pi / 4) * \text{Sqr}(3.1250) * 50.00 = 383 \text{ lb}$$

$$H_p = 2b(\pi)GmP = 2 * 0.2500 * \pi * 3.1250 * 2.80 * 50.00 = 687 \text{ lb}$$

$$\text{Min. } W_{m1} = H + H_p = 383 + 687 = 1070 \text{ lb}$$

$$A_{m1} = W_{m1} / S_b = 1070 / 14872 = 0.0719 \text{ in}^2$$

$$A_{m2} = W_{m2} / S_a = 7731 / 18800 = 0.4112 \text{ in}^2$$

$$A_m = \text{greater of } A_{m1} \text{ or } A_{m2} = \text{greater of } 0.0719 \text{ or } 0.4112 = 0.4112 \text{ in}^2$$

$$A_b = \text{No. of bolts} * \text{Bolt root area} = 4 * 0.2020 = 0.8080 \text{ in}^2$$

$$W = (A_m + A_b)S_a/2 = (0.4112 + 0.8080) * 18800 / 2 = 11460 \text{ lb}$$

Thickness Calculations

$$hG = (C - G) / 2 = (4.3750 - 3.1250) / 2 = 0.6250 \text{ in.}$$

$$\text{Min. } t \text{ (Operating)} = G * \text{SgRt}(CP / SE + 1.9 W_{m1} hG / SE G^3) =$$

$$3.1250 * \text{SgRt}(0.300 * 50.00 / 14632 * 1.00 +$$

$$1.9 * 1070 * 0.6250 / 14632 * 1.00 * 3.1250^3) = 0.1944 \text{ in.}$$

$$\text{Min. } t \text{ (Seating)} = G * \text{SgRt}(1.9 W hG / SE G^3) = 3.1250 *$$

$$\text{SgRt}(1.9 * 11460 * 0.6250 / 14632 * 1.00 * 3.1250^3) = 0.5169 \text{ in.}$$

$$\text{Min. } t = \max(0.1944, 0.5169) + CA = 0.5169 + 0.0000 = 0.5169 \text{ in.}$$

Minimum thickness = 0.5169 in.

Nominal thickness = 0.7500 in.

$A_b \geq A_m$, bolting is adequate for flange design.

Nominal $t \geq$ Minimum t , flange thickness is adequate for flange design.

Item	Design Pressure	Static Head	MAWP New & Cold	MAWP Hot & Corr.
MAIN SHELL	50.00	0.00	433.37	409.75
Nozzle No. A1	50.00	0.00	509.84	482.27
ANSI Flange Cl: 150 Gr:2.3,	50.00	0.00	230.00	167.00
Nozzle No. P1, P2 & A2	50.00	0.00	509.84	482.27
ANSI Flange Cl: 150 Gr:2.3,	50.00	0.00	230.00	167.00
END CAP	50.00	0.00	441.10	417.24
Nozzle No. V1 & B1	50.00	0.00	567.39	536.71
ANSI Flange Cl: 150 Gr:2.3,	50.00	0.00	230.00	167.00
2" 150# BLIND FLANGE	50.00	0.00	709.35	561.14

-- SUMMARY --

New and cold component with lowest MAWP: (MAWP = 230.00 PSI)

 ANSI Flange Cl: 150 Gr:2.3, 31

Hot and corroded component with lowest MAWP: (MAWP = 167.00 PSI)

 ANSI Flange Cl: 150 Gr:2.3, 31

Pressures are exclusive of any external loads.

Item	Material	Curve Pressure	MDMT
MAIN SHELL	SA-312, Type TP316L, WLD	exempt per UHA-51(a)	
Nozzle No. A1	SA-312 TP316L WLD	exempt per UHA-51(a)	
Nozzle No. P1, P2 & A2	SA-312 TP316L WLD	exempt per UHA-51(a)	
END CAP	SA-403, Type 316L WP-W	exempt per UHA-51(a)	
Nozzle No. V1 & E1	SA-312 TP316L WLD	exempt per UHA-51(a)	
2" 150# BLIND FLANGE	SA-182 F316L	exempt per UHA-51(a)	

-- SUMMARY --

All components meet MDMT requirements.

WEIGHTS:

	dry	flooded
Shell weight	125 Lbs.	307 Lbs.
Head weight	6 Lbs.	13 Lbs.
Nozzle weight	65 Lbs.	65 Lbs.
Flange weight	6 Lbs.	6 Lbs.
Total Weights	203 Lbs.	390 Lbs.

VOLUME:

Shell volume	21.73 Gallons
Head volume	0.76 Gallons
Total Volume	22.49 Gallons

AREA:

Shell area	23 Sq. Ft.
Head area	1 Sq. Ft.
Total Area	24 Sq. Ft.

HYDROSTATIC TEST INFORMATION
Gauge at Top

Controlling Components

Ratio: MAIN SHELL
Pressure: MAIN SHELL

$$\text{Design Pressure} * 1.5 * (\text{Cold Stress} / \text{Hot Stress}) = \text{Hydro Test Pressure}$$

$$50.00 * 1.5 * (14200 / 13432) = 79.29 \text{ PSI}$$

Supp. Log PER PRESSURE VESSEL HANDBOOK
 SH Editor BY ~~MEGYSEY MEGYSEY~~ EMEGYESY.
 LOAD PER LOG. 1,400 lbs.